



Certificate of
constancy of performance
0560-CPR-202190036
Issue: 01



Issued	06-06-2024	Replaces	0560-CPR-202190036 / 00
First issued	20-01-2022	Page	1 / 2

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

Product description:	Smoke and CO detector
Trademark:	MikroTik
Type designation:	SD1-CC2
Hardware / Software:	MTA203304 / 2.1.0
Conditions and essential characteristics:	See Annex 1
Variants:	See Annex 1

placed on the market under the name or trademark of:

Name of the manufacturer:	Mikrotikls SIA
Address:	Ūnijas iela 2
City:	LV-1039 Riga
Country:	Latvia

and produced in the manufacturing plant(s):

Manufacturing plant:	SELTEKA UAB
Address:	Draugystės g. 19
City:	51230 Kaunas
Country:	Lithuania

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s):

EN 14604:2005
EN 14604:2005/AC:2008

under system 1 for the performances set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the **constancy of performance of the construction product**

This certificate was first issued on 20-01-2022 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Ron Scheepers
Managing director

Kiwa Nederland B.V.
Kiwa FSS Products
Wilmsdorf 50
Postbus 137
7300 AC Apeldoorn
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>

Notified Body No. 0063



Remarks and observations

The following conditions are applicable:

Essential characteristics of EN 14604:	Clauses:	Performance
Nominal activation conditions/ Sensitivity, Response delay (response time) and Performance under fire condition	4.12, 4.18, 5.2, 5.3, 5.4, 5.5, 5.6, 5.15, 5.17, 5.18, 5.19, 5.20	Pass
Operational reliability	4.1, 4.2, 4.6, 4.7, 4.9, 4.10, 4.13, 4.14, 4.15, 4.16, 4.17, 4.19, 5.11, 5.16, 5.22, 5.24	Pass
Tolerance to supply voltage	5.21	Pass
Durability of operational reliability and response delay, temperature resistance	5.7, 5.8	Pass
Durability of operational reliability, vibration resistance	5.12, 5.13	Pass
Durability of operational reliability, humidity resistance	5.9	Pass
Durability of operational reliability, corrosion resistance	5.10	Pass
Durability of operational reliability, electrical stability	5.14	Pass

The product as described in this certificate includes the following type designations

- Product description: Smoke and CO detector
- Trademark: MikroTik
- Type designation: SD1-CC2
- Hardware version: MTA203304
- Software version: 2.1.0

- Product description: Smoke detector
- Trademark: MikroTik
- Type designation: SD1-C2
- Hardware version: MTA203304
- Software version: 2.1.0

- Product description: Smoke detector
- Trademark: MikroTik
- Type designation: SD1
- Hardware version: MTA203304
- Software version: 2.1.0